NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016535
DATE: 03/12/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products **5020 Weston Parkway** **Cary, NC 27513**	**Series "2300" 2392** **Vinyl Horizontal Sliding Window** **(Fin)** Configuration: XO Glazing: Insulating Glass (Annealed) Frame: W-1854mm(73") H-1600mm(63") Sash: W-921mm(36.25") H-1553mm(61.13") DLO: W-860mm(33.88") H-1489mm(58.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 **AAMA/WDMA/CSA 101/I.S.2/A440-08**	**Class R-PG15 1854 x 1600 (73 x 63)-HS** **Design Pressure: ±720 Pa (±15 psf)** **Water Penetration Resistance Test Pressure: 110 Pa (2.92 psf)**

Product Tested By: Intertek, PLC
Report No: D9960.01-109-47
Expiration Date: **March 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com