NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016538
DATE: 03/12/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products **5020 Weston Parkway** **Cary, NC 27513**	**Series "5500" 5510/5540** **Vinyl Sidelite** Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1245mm(49") H-2432mm(95.75") DLO: W-1092mm(43") H-2261mm(89")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	**Class R-PG35 1245 x 2432 (49 x 96)-SLT** **Design Pressure: ±1680 Pa (±35 psf)** **Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)**

Product Tested By: Intertek, PLC
Report No: E6290.01-109-47
Expiration Date: **March 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com