

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016549
DATE: 03/25/2025
CERTIFICATION PROGRAM: Fire
COMPANY: Jameson Supply
CODE: 3037-1
EXPIRATION DATE: 03/31/2029

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Jameson Supply, LLC 2755 South Beverly, #101 Boise, ID 83709	Lynden 20 Minute L20SP Wood Core Fire Door Assembly Manufacturer Specific Fire Doors for Single and Double Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw for Singles 3/4" Minimum Latch Throw for Double Single & Double Swing Only Single Maximum Size: 4'0" x 9'0" Single Maximum Size: 3'6" x 10'0" Double Maximum Size: 8'0" x 9'0" Double Egress Maximum Size: 8'0" x 8'0" Dutch Door: 4'0" x 8'0" Door w/Transom Maximum Size: 4'0" x 10'0" Transom Maximum Size: 3'0" x 3'4" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008)(2012) UL 10C (2001)(2009)(2016) UL 10B (2008)(2009) UBC Standard 7-2 (1994)(1997)(2015) CAN/ULC S104 (1985)(2010) CSFM 43.7	20 Minute-Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required (unless specified in individual manufacturer's listing) For Use in Category C-Standard Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)
TEST REPORT	
Intertek Test Report No: 491-7972/3052139/3060684/3075954/3157236/103140421	

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC-03/30/2023

