# NOTICE OF PRODUCT CERTIFICATION

**CERTIFICATION NO:** NI016562
**DATE:** 03/26/2025
**CERTIFICATION PROGRAM:** Structural
**COMPANY:** Crystal Window
**CODE:** 1774-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| **Crystal Window and Door Systems Corp.**<br>**31-10 Whitestone Expressway**<br>**Flushing, NY 11354** | **Series "DH 2700"**<br>**Aluminum Double Hung Window**<br>Configuration: X/X<br>Glazing: Insulating Glass (Annealed)<br>Frame: W-1524mm(60") H-2515mm(99")<br>Sash: W-1454mm(57.25") H-1264mm(49.75")<br>DLO: W-1273mm(50.13") H-1051mm(41.38") |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| **AAMA/WDMA/CSA 101/I.S.2/A440-17** | **Class AW-PG50 1524 x 2515 (60 x 99)-H**<br>**Design Pressure: ±2400 Pa (±50 psf)**<br>**Water Penetration Resistance Test Pressure: 480 Pa (10.03 psf)** |

Product Tested By: Molimo, LLC
Report No: 11716.03-106-12
Expiration Date: **April 30, 2030**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.**
**4794 George Washington Memorial Highway**
**Hayes, VA 23072**
**Tel: (804) 684-5124**
**Email: nami@namiinc.com**