NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016570
DATE: 03/26/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products **5020 Weston Parkway** **Cary, NC 27513**	**Series "2127" Impact** **Vinyl Tilt Single Hung Window** **(Frame & Fin Installations)** Configuration: O/X Glazing: IG-Ext. 1/8" Annealed Glass/Int.-3/32" Annealed Glass/0.090" Solutia Saflex PVB Interlayer/3/32" Annealed Glass Frame: W-1321mm(52") H-1854mm(73") Sash: W-1270mm(50") H-918mm(36.13") DLO: W-1210mm(47.63") H-854mm(33.63")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	**Design Pressure: +55/-60 psf** **Water Penetration Resistance Test Pressure: 395 Pa (8.25 psf)** **Large Missile Impact Rated**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-16327-1
Expiration Date: **March 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com