NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016572
DATE: 03/31/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Vistamark
CODE: 2165-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Vistamark Enterprises, LLC **3581 S. Hwy 287** **Waxahachie, TX 75165**	**Series "Endura 101"** **Vinyl Fixed Window** Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-2134mm(84") H-2134mm(84") DLO: W-2007mm(79") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **AAMA/WDMA/CSA 101/I.S.2/A440-17**	**Class LC-PG55 2134 x 2134 (84 x 84)-FW** **Design Pressure: ±2640 Pa (±55 psf)** **Water Penetration Resistance Test Pressure: 580 Pa (12.12 psf)** **Canadian Air Infiltration/Exfiltration Level: A3**

Product Tested By: Molimo, LLC
Report No: 29998.02-109-12
Expiration Date: **February 28, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com