NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016576
DATE: 04/01/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products **5020 Weston Parkway** **Cary, NC 27513**	**Series "70" 2100HV Non-Impact** **Vinyl Single Hung Window** **(Fin & Flange)** Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1321mm(52") H-1588mm(62.50") DLO: W-1211mm(47.69") H-718mm(28.25")

SPECIFICATION	PRODUCT RATING
TAS 202-94	**Design Pressure: +55/-60 psf** **Water Penetration Resistance Test Pressure: 470 Pa (9.75 psf)**

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01410311
Expiration Date: **March 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com