NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016586
DATE: 04/10/2025
CERTIFICATION PROGRAM: Fire
COMPANY: Harvey
CODE: 310-1
EXPIRATION DATE: 04/30/2029

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Harvey Building Products **30 Jack's Bridge Road** **Londonderry, NH 03053**	**Plastpro's 20 Minute Flush or Embossed Fiberglass Single Swing Door Assembly** SMC Fiberglass Embossed Skin Door w/Polyurethane Core For Single Swing Installation in 20 Minute Locations ½" Minimum Latch Throw Single Swing Only **Maximum Size: 3'0" x 6'8"**

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008) **UL 10C (2001) (2009)**	**20 Minute-Without Hose Stream** **Positive Pressure** **Category B Door-Requires Additional Listed Edge Seal** **For Use in Category C Frame** **(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)**

TEST REPORT	EVALUATION REPORT
Intertek Test Report No: 31655MID-006/3182549MID-005b	**Intertek Engineering Evaluation Report No: 3182549MID-008**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com