NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016598
DATE: 04/10/2025
CERTIFICATION PROGRAM: Structural
COMPANY: A Window
CODE: 412-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
A Window, Inc. **6201-C Dowdell Road** **Fort Worth, TX 76119**	**Series "EC Double Slider"** **Vinyl Horizontal Sliding Window** Configuration: OX Glazing: Insulating Glass (Annealed) Frame: W-1600mm(63") H-1118mm(44") Sash: W-786mm(30.94") H-1006mm(39.63") DLO: W-695mm(27.38") H-918mm(36.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	**Class LC-PG70 1600 x 1118* (63 x 44*)-HS** **Design Pressure: ±3360 Pa (±70 psf)** **Water Penetration Resistance Pressure: 510 Pa (10.65 psf)**

Product Tested By: Molimo, LLC
Report No: 30706.01-106-11/30705.01-106-11
Expiration Date: **August 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com