

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016600.05  
**DATE:** 04/14/2025  
**CERTIFICATION PROGRAM:** MFG HSG  
**COMPANY:** Trimco Millwork  
**CODE:** 868-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Trimco Millwork</b>  <b>1835 Commerce Avenue</b>  <b>Boise, ID 83715</b>	<b>Plastpro 3'0" x 6'8" Glazed</b>  <b>Fiberglass In-Swing Side Hinged Door</b>  <b>(w/Sidelites &amp; Composite Jambs)</b>  Configuration: OXO  Frame: W-1743mm(68.63") H-2083mm(82") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-537mm(21.13") H-1604mm(63.13") STP: Pos+2298 Pa (48 psf) Neg-2298 Pa (48 psf)

SPECIFICATION	PRODUCT RATING
<b>AAMA 1702.2-95/12</b> <b>Federal Manufactured Home Construction</b> <b>&amp; Safety Standard 3280.405</b>	<b>Manufactured Housing-Passed</b> <b>Wind Zone II</b> <b>Design Wind Pressure Rating:</b> <b>+48/-48 psf</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
 Report No: TEL 01393402/W-2142  
 Expiration Date: April 30, 2027

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND**  
**MANAGEMENT INSTITUTE, INC.**  
 4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)