NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI015758.01
DATE: 05/01/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Heartland
CODE: 1018-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Heartland Window Manufacturing **18517 Highway 57** **Aplington, Iowa 50604**	**Series "2030 "** **Vinyl Sliding Glass Door** Configuration: OX Glazing: Insulating Glass (Tempered) Frame: W-2438mm(96") H-2438mm(96") Panel: W-1235mm(48.63") H-2381mm(93.75") DLO: W-1084mm(42.69") H-2226mm(87.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	**Class R-PG20 2438 x 2438 (96 x 96)-SD** **Design Pressure: ±960 Pa (±20 psf)** **Water Penetration Resistance Test Pressure: 150 Pa (3.13 psf)** **Canadian Air Infiltration/Exfiltration Level: A2**

Product Tested By: Intertek PLC
Report No: S2374.02-901-44
Expiration Date: **March 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com