NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016650.01
DATE: 05/15/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Target
CODE: 1641-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Target Windows & Doors, Inc. **800 West State Street** **Vandalia, MO 63382**	**Series "System 190"** **Vinyl Fixed Window** Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1372mm(54") H-1626mm(64") DLO: W-1295mm(51") H-1549mm(61")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	**Class CW-PG65 1372 x 1626* (54 x 64*)-FW** **Design Pressure: ±3120 Pa (±65 psf)** **Water Penetration Resistance Test Pressure: 470 Pa (9.82 psf)**

Product Tested By: Intertek.
Report No: Q8568.01-109-44
Expiration Date: **March 31, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com