NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016363.01
DATE: 06/24/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Vistamark
CODE: 2165-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Vistamark Enterprises, LLC **3581 S. Hwy 287** **Waxahachie, TX 75165**	**Series "Endura 210"** **Vinyl Single Hung Window** Configuration: O/X Glazing: IG-Ext. 1/8" Annealed Glass/Int.1/8" Annealed Glass/0.090" Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-1219mm(48") H-1829mm(72") Sash: W-1146mm(45.13") H-914mm(36") DLO: W-1048mm(41.25") H-816mm(32.13")

SPECIFICATION	PRODUCT RATING
ASTM E1886-19 **ASTM E1996-20**	**Design Pressure: ±2400 Pa (±50 psf)** **Wind Zone 3 - Missile Level D**

Product Tested By: Molimo, LLC
Report No: 30872.02-109-12
Expiration Date: **May 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com