NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016669
DATE: 06/04/2025
CERTIFICATION PROGRAM: Structural
COMPANY: United
CODE: 2779-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
United Window & Door Manufacturing **24-36 Fadem Road** **Springfield, New Jersey 07081**	**Series "3900"** **Vinyl Horizontal Slider Window** Configuration: XOX Glazing: Insulated Glass (Annealed) Frame: W-2731mm(107.50") H-1511mm(59.50") Sash: W-889mm(35") H-1435mm(56.50") DLO: W-829mm(32.63") H-1372mm(54")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **AAMA/WDMA/CSA 101/I.S.2/A440-17**	**Class R-PG20 2731 x 1511 (108 x 60)-HS** **Design Pressure: ±960 Pa (±20 psf)** **Water Penetration Resistance Test Pressure: 220 Pa (4.60 psf)**

Product Tested By: Molimo, LLC
Report No: 30728.01-106-12
Expiration Date: **April 30, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com