

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016678
DATE: 06/12/2025
CERTIFICATION PROGRAM: Structural
COMPANY: New Erra
CODE: 1345-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
New Erra Doors, LLC 2787 N. Airport Road, #411 Fort Myers, FL 33907	“Opaque Inswing Entrance Doors” Wood Opaque Inswing Side Hinged Doors Configuration: XX Frame: W-2518mm(99.13") H-3132mm(123.31") Panel: W-1219mm(48") H-3048mm(120")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	Class CW-PG75 2518 x 3132 (99 x 123)-LW SHD Design Pressure: ±3600 Pa (±75 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)

Product Tested By: QAI Laboratories
Report No: MED-1064d
Expiration Date: November 30, 2028

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com