

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016680.01
DATE: 06/11/2025
CERTIFICATION PROGRAM: Structural
COMPANY: New Erra
CODE: 1345-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>New Erra Doors, LLC 2787 N. Airport Road, #410 Fort Myers, FL 33907</p>	<p style="text-align: center;">“Glazed Inswing Entrance Door ”</p> <p style="text-align: center;">Wood Glazed Inswing Side Hinged Door</p> <p style="text-align: center;">(w/Sidelites)</p> <p style="text-align: center;">Configuration: OXXO Glazing: IG-1/4" Heat Strengthened Glass/0.090" SentryPlus PVB Interlayer/1/4" Heat Strengthened Glass AND 1/4" Tempered Glass/0.090" SentryPlus PVB Interlayer/1/4" Tempered Glass</p> <p>Frame: W-4585mm(180.50") H-3132mm(123.31")</p> <p>Panel: W-1219mm(48") H-3048mm(120")</p> <p>DLO: W-1016mm(40") H-3023mm(119")</p>

SPECIFICATION	PRODUCT RATING
<p>TAS 201/203-94 TAS 202-94 (Structural Only) ASTM E1886-19 ASTM E1996-17</p>	<p>Design Pressure: +75/-75 psf Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Missile Level D Large Missile Impact Rated</p>

Product Tested By: QAI Laboratories
 Report No: MED-1064c/MED-1064d
 Expiration Date: November 30, 2028

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Email: nami@namiinc.com