

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016681.01  
**DATE:** 06/12/2025  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** New Erra  
**CODE:** 1345-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>New Erra Doors, LLC</b> <b>2787 N. Airport Road, #410</b> <b>Fort Myers, FL 33907</b>	<b>“Glazed Inswing Entrance Door ”</b> <b>Wood Glazed Inswing Side Hinged Door</b>  Configuration: XX Glazing: IG-1/4" Tempered Glass/0.090 SentryGlas Plus PVB Interlayer/1/4" Tempered Glass <b>AND</b> 3/16" Tempered Glass/0.090" SentryGlas Plus PVB Interlayer/3/16" Tempered Glass  Frame: W-2518mm(99.13") H-3132mm(123.31")  Panel: W-1219mm(48") H-3048mm(120")  DLO: W-876mm(34.50") H-3023mm(119")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/203-94</b> <b>TAS 202-94 (Structural Only)</b> <b>ASTM E1886-19</b> <b>ASTM E1996-17</b>	<b>Design Pressure: +75/-75 psf</b> <b>Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)</b> <b>Missile Level D</b> <b>Large Missile Impact Rated</b>

Product Tested By: QAI Laboratories  
Report No: MED-1064c/MED-1064d  
Expiration Date: November 30, 2028

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shirley", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023