

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016682  
**DATE:** 06/12/2025  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** New Erra  
**CODE:** 1345-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>New Erra Doors, LLC</b> <b>2787 N. Airport Road, #410</b> <b>Fort Myers, FL 33907</b>	<b>“Glazed Inswing Entrance Door ”</b> <b>Wood Glazed Inswing Side Hinged Door</b> <b>(w/Sidelites &amp; Transom)</b>  Configuration: O/OO/XXO/O Glazing: IG-3/16" Heat Strengthened Glass/0.090 SentryGlas Plus PVB Interlayer/3/16" Heat Strengthened Glass  Frame: W-4572mm(180") H-4382mm(172.50") Panel: W-1219mm(48") H-3048mm(120") DLO: W-876mm(34.50") H-3023mm(119")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-22</b>	<b>Class CW-PG75 4572 x 4382 (180 x 173)-SHD</b> <b>Design Pressure: ±3600 Pa (±75 psf)</b> <b>Water Penetration Resistance Test Pressure: 540 Pa (11.20 psf)</b>

Product Tested By: QAI Laboratories  
Report No: MED-1064d  
Expiration Date: November 30, 2028

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)