NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016746.08
DATE: 07/31/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Glass Craft
CODE: 1157-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Glass Craft Door Corporation **2002 Brittmoore Road** **Houston, TX 77043-2209**	**Series "Value Series FiberCraft"** **Flush Glazed (BBG) Inswing Fiberglass Side-Hinged Door** Configuration: X Glazing: Insulated Glass (Tempered) Frame: W-953mm(37.5") H-2083mm(82") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-635mm(25") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-12 **Federal Manufactured Home Construction & Safety Standard 3280.305**	**Manufactured Housing-Passed** **Wind Zone III** **Design Wind Pressure Rating:** **+58/-58 psf**

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 06043984
Expiration Date: **July 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com