NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016776.01**
DATE:	**07/29/2025**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Dyke Ind**
CODE:	**3197-1**
REVISION DATE:	**08/04/2025**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Dyke Industries **1360 Harrison Brookville Road** **West Harrison, IN 47060**	**Glazed Inswing Fiberglass** **Side-Hinged Door Assembly** Configuration: XX Glazing: Insulated Glass (Tempered) Frame: W-1816mm(71.5") H-2019mm(79.5") Panel: W-876mm(34.5") H-1956mm(77") DLO: W-530mm(20.88") H-1594mm(62.75")

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-12 **Federal Manufactured Home Construction & Safety Standard 3280.305**	**Manufactured Housing-Passed** **Wind Zone I** **Design Wind Pressure Rating:** **+25/-12.5 psf**

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 04602492
Expiration Date: **July 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com