# NOTICE OF PRODUCT CERTIFICATION

**CERTIFICATION NO:** NI016778.10
**DATE:** 08/28/2025
**CERTIFICATION PROGRAM:** Structural
**COMPANY:** JELD WEN
**CODE:** 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| **JELD-WEN**<br>**3737 Lakeport Boulevard**<br>**Klamath Falls, OR 97601** | **Series "Design Pro/Smooth Pro (F-3500)**<br>**Fiberglass Swinging Door"**<br>**Opaque Fiberglass**<br>**Inswing Side Hinged Door**<br>Configuration: XX<br>Frame: W-1880mm(74") H-2076mm(81.75")<br>Panel: W-908mm(35.75") H-2010mm(79.13") |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| **AAMA/WDMA/CSA 101/I.S.2/A440-22**<br>**AAMA/WDMA/CSA 101/I.S.2/A440-17**<br>**CSA A440S1-17**<br>**ASTM E1886-19**<br>**ASTM E1996-20** | **Class R-PG50 1880 x 2076 (74 x 82)-LW SHD**<br>**Design Pressure: ±2400 Pa (±50 psf)**<br>**Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)**<br>**Canadian Air Infiltration/Exfiltration Level: A3**<br>**Missile Level D/Wind Zone 3** |

Product Tested By: Molimo, LLC
Report No: 31253.01-201-12
Expiration Date: **July 31, 2029**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.**
**4794 George Washington Memorial Highway**
**Hayes, VA 23072**
**Tel: (804) 684-5124**
**Email: nami@namiinc.com**