

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016784.06
DATE: 08/13/2025
CERTIFICATION PROGRAM: MFG HSG
COMPANY: Mariotti
CODE: 1891-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Mariotti Building Products 1 Louis Industrial Drive Old Forge, PA 18518	Plastpro 6'0" x 6'8" Glazed Fiberglass In-Swing Side Hinged Door (w/ Composite Jambs) Configuration: XX Frame: W-1880mm(74") H-2083mm(82") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-537mm(21.13") H-1604mm(63.13") STP: Pos+2298 Pa (48 psf) Neg-2298 Pa (48 psf)

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95/12 Federal Manufactured Home Construction & Safety Standard 3280.405	Manufactured Housing-Passed Wind Zone II Design Wind Pressure Rating: +48/-48 psf

Product Tested By: Testing Evaluation Laboratories, Inc.
 Report No: TEL 01393403/W-2142
 Expiration Date: August 31, 2027

Administrator's Signature: _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com