

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016784.09
DATE: 08/14/2025
CERTIFICATION PROGRAM: MFG HSG
COMPANY: Mariotti
CODE: 1891-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Mariotti Building Products 1 Louis Industrial Drive Old Forge, PA 18518	Plastpro 3'0" x 6'8" Opaque Fiberglass In-Swing Side Hinged Door (w/Sidelites & Composite Jambs) Configuration: OXO Frame: W-1743mm(68.63") H-2083mm(82") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-152mm(6") H-1600mm(63") STP: Pos+2777 Pa (58 psf) Neg-2777 Pa (58 psf)

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95/12 Federal Manufactured Home Construction & Safety Standard 3280.405	Manufactured Housing-Passed Wind Zone III Design Wind Pressure Rating: +58/-58 psf

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01393406/W-2142
Expiration Date: August 31, 2027

Administrator's Signature:  _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com