

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016784  
DATE: 08/13/2025  
CERTIFICATION PROGRAM: MFG HSG  
COMPANY: Mariotti  
CODE: 1891-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS   | PRODUCT DESCRIPTION  |
|--|--|
| <b>Mariotti Building Products</b><br><b>1 Louis Industrial Drive</b><br><b>Old Forge, PA 18518</b> | <b>Plastpro 3'0" x 6'8" Glazed</b><br><b>Fiberglass In-Swing Side Hinged Door</b><br><b>(w/Composite Jambs)</b><br><br>Configuration: X<br><br>Frame: W-953mm(37.5") H-2083mm(82")<br>Panel: W-908mm(35.75") H-2013mm(79.25")<br>DLO: W-629mm(24.75") H-1594mm(62.75")<br>STP: Pos+2777 Pa (58 psf) Neg-2777 Pa (58 psf) |

| SPECIFICATION  | PRODUCT RATING  |
|--|---|
| <b>AAMA 1702.2-95/12</b><br><b>Federal Manufactured Home Construction</b><br><b>&amp; Safety Standard 3280.405</b> | <b>Manufactured Housing-Passed</b><br><b>Wind Zone III</b><br><b>Design Wind Pressure Rating:</b><br><b>+58/-58 psf</b> |

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01393397/W-2142  
Expiration Date: August 31, 2027

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)