NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016785.03
DATE: 08/13/2025
CERTIFICATION PROGRAM: MFG HSG
COMPANY: Dyke Ind
CODE: 3197-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Dyke Industries **1360 Harrison Brookville Road** **West Harrison, IN 47060**	**Plastpro 3'0" x 6'8" Glazed** **Fiberglass In-Swing Side Hinged Door** **(w/Sidelite & Composite Jambs)** Configuration: OX Frame: W-1892mm(74.5") H-2083mm(82") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-629mm(24.75") H-1594mm(62.75") STP: Pos+2777 Pa (58 psf) Neg-2777 Pa (58 psf)

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95/12 **Federal Manufactured Home Construction & Safety Standard 3280.405**	**Manufactured Housing-Passed** **Wind Zone III** **Design Wind Pressure Rating:** **+58/-58 psf**

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01393400/W-2142
Expiration Date: **August 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com