

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016810
DATE: 09/24/2025
CERTIFICATION PROGRAM: MFG HSG
COMPANY: Trimco Millwork
CODE: 868-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Trimco Millwork 1835 Commerce Avenue Boise, ID 83715	Series "Opaque" Steel Inswing Door Configuration: X Frame: W-953mm(37.5") H-2070mm(81.5") Panel: W-908mm(35.75") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95/12 Federal Manufactured Home Construction & Safety Standard 3280.305	Manufactured Housing-Passed Wind Zone III Design Wind Pressure Rating: +58/-58 psf

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01522273/W-2140
Expiration Date: September 30, 2027

A handwritten signature in black ink, appearing to be 'Shirley'.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC-03/30/2024