

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016825
DATE: 10/13/2025
CERTIFICATION PROGRAM: Structural
COMPANY: MAISON JAN
CODE: 2883-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Maison Janneau, LLC 5555 N Lamar Blvd., Suite L125 Austin, Texas 78751	Series "Eiffel Fineline 70" Steel Casement Window Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1038mm(40.88") H-2038mm(80.25") Vent: W-1000mm(39.38") H-2007mm(79") DLO: W-914mm(36") H-1915mm(75.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	Class CW-PG30 1038 x 2038 (41 x 80)-C Design Pressure: ±1440 Pa (±30 psf) Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)

Product Tested By: Intertek, PLC
Report No: Q5094.02-109-44
Expiration Date: **December 31, 2027**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com