

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015212.03
DATE: 12/09/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Sun-Tek
CODE: 225-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Sun-Tek Manufacturing, Inc. 10303 General Drive Orlando, FL 32824	Series "FGC" Aluminum Fixed Glass Roof Skylight Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1372mm(54") H-1372mm(54") DLO: W-1156mm(45.5") H-1156mm(45.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class SKG-PG90 1372 x 1372 (54 x 54) Design Pressure: ±4320 Pa (±90 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf)

Product Tested By: PRI Construction Materials Technologies LLC
Report No: 2594T0005
Expiration Date: November 30, 2029

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com