NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016863.03
DATE: 12/11/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Milliken
CODE: 994-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Milliken Millwork, Inc. **6361 Sterling Drive North** **Sterling Heights, MI 48312**	**Series "Contours (S-2500) Steel Wood Swinging Door"** **Glazed Steel Outswing Side Hinged Door** Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-953mm(37.50") H-2463mm(97") Panel: W-908mm(35.75") H-2416mm(95.13") DLO: W-530mm(20.88") H-2000mm(78.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **AAMA/WDMA/CSA 101/I.S.2/A440-17** **CSA A440S1-17**	**Class LC-PG35 953 x 2463 (38 x 97)-LW SHD** **Design Pressure: 1680 Pa (35 psf)** **Negative Design Pressure: 1920 Pa (40 psf)** **Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)** **Canadian Air Infiltration/Exfiltration Level: A2**

Product Tested By: Molimo, LLC
Report No: 31061.01-201-12
Expiration Date: **December 31, 2029**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com