

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016882
DATE: 01/15/2026
CERTIFICATION PROGRAM: Structural
COMPANY: New Erra
CODE: 1345-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>New Erra Doors, LLC 2787 N. Airport Road, #410 Fort Myers, FL 33907</p>	<p style="text-align: center;">“Outswing Entrance Doors”</p> <p>Wood Glazed Outswing Side Hinged Doors</p> <p style="text-align: center;">Configuration: XX Glazing: IG-1/4" Heat Strengthened Glass/0.090" Kuraray SentryGlas PVB Interlayer/1/4" Heat Strengthened Glass OR 3/16" Heat Strengthened Glass/0.090" Kuraray SentryGlas PVB Interlayer/3/16" Heat Strengthened Glass</p> <p>Frame: W-2518mm(99.13") H-3113mm(122.56") Panel: W-1219mm(48") H-3048mm(120") DLO: W-864mm(34") H-2642mm(104")</p>

SPECIFICATION	PRODUCT RATING
<p>AAMA/WDMA/CSA 101/I.S.2/A440-22 TAS 201/202/203-94 ASTM E1886-19 ASTM E1996-17</p>	<p>Class CW-PG75 2518 x 3113 (99 x 123)-SHD Design Pressure: ±3600 Pa (±75 psf) Water Penetration Resistance Test Pressure: 536 Pa (11.20 psf) Missile Level D Large Missile Impact Rated</p>

Product Tested By: QAI Laboratories
 Report No: MED-1062a/MED-1062b
 Expiration Date: November 30, 2028

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Email: nami@namiinc.com