# NOTICE OF PRODUCT CERTIFICATION

| | |
|---|---|
| **CERTIFICATION NO:** | **NI016886 .01-R1** |
| **DATE:** | **01/15/2026** |
| **CERTIFICATION PROGRAM:** | **Structural** |
| **COMPANY:** | **Vistamark** |
| **CODE:** | **2165-1** |
| **REVISION DATE:** | **06/10/2026** |

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| **Vistamark Enterprises, LLC**<br>**3581 S. Hwy 287**<br>**Waxahachie, TX 75165** | **Series Endura 130 Fixed Lite Slider 3-SL**<br>**Vinyl Horizontal Sliding Window**<br>Configuration: XOX<br>Glazing: Insulating Glass (Annealed)<br>Frame: W-2743mm(108") H-1422mm(56")<br>Sash: W-667mm(26.25") H-1353mm(53.25")<br>DLO: W-584mm(23") H-1270mm(50") |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| **AAMA/WDMA/CSA 101/I.S.2/A440-22**<br>**AAMA/WDMA/CSA 101/I.S.2/A440-17** | **Class R-PG50 2743 x 1422 (108 x 56)-HS**<br>**Design Pressure: ±2400 Pa (±50 psf)**<br>**Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)**<br>**Canadian Air Infiltration/Exfiltration Level: A3** |

Product Tested By: Molimo, LLC
Report No: 32019.02-109-12
Expiration Date: **October 31, 2029**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.**
**4794 George Washington Memorial Highway**
**Hayes, VA 23072**
**Tel: (804) 684-5124**
**Email: nami@namiinc.com**