NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016904-R1**
DATE:	**02/23/2026**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Montleau Invest.**
CODE:	**3247-1**
REVISION DATE:	**07/07/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Montleau Investment, Inc. **19089 Colima Road,** **Rowland Heights, CA 91748**	**Series "CCl 92"** **Aluminum Clad Wood Fixed Window** Configuration: O Triple Glazing: Insulating Glass (Tempered) Frame: W-1500mm(59.06") H-1500mm(59.06") DLO: W-1324mm(52.13") H-1324mm(52.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101.I.S.2/A440-22	**Class CW-PG60 1500 x 1500 (59 x 59)-FW** **Design Pressure: +60/-60 psf** **Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf)**

Product Tested By: Intertek, PLC
Report No: 250815007SHF-002
Expiration Date: **September 30, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com