NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016923.01
DATE: 03/11/2026
CERTIFICATION PROGRAM: Structural
COMPANY: ViWinTech
CODE: 583-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ViWinTech **2400 Irvin Cobb Drive** **Paducah, KY 42003**	**Series "1250 Fixed Picture Window"** **Vinyl Fixed Window** Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1524mm(60") H-1524mm(60") DLO: W-1422mm(56") H-1422mm(56")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **AAMA/WDMA/CSA 101/I.S.2/A440-17**	**Class CW-PG80 1524 x 1524 (60 x 60)-FW** **Design Pressure: ±3840 Pa (±80 psf)** **Water Penetration Resistance Test Pressure: 580 Pa (12.12 psf)**

Product Tested By: Molimo, LLC.
Report No: 32110.02-109-12
Expiration Date: **November 30, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com