NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016926.01
DATE: 03/11/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Crystal Window
CODE: 1774-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Crystal Window and Door Systems Corp. **31-10 Whitestone Expressway** **Flushing, NY 11354**	**Series "800 Oriel"** **Vinyl Single Hung Window** Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1207mm(47.50") H-2426mm(95.50") Sash: W-1153mm(45.38") H-727mm(28.63") DLO: W-1092mm(43") H-667mm(26.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **AAMA/WDMA/CSA 101/I.S.2/A440-17**	**Class LC-PG35 1207 x 2426 (48 x 96)-H** **Design Pressure: ±1680 Pa (±35 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)** **Canadian Air Infiltration/Exfiltration Level: A2**

Product Tested By: Molimo, LLC
Report No: 31945.03-109-12
Expiration Date: **October 29, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com