Notice of Product Certification

Company: Les Chassis Nigadoo

Address: 356 du Moulin Street Nigadoo, NB, Canada E8K 3W1
Code: 1179-1
Certification No: 1179-003
Certification Date: April 15, 2026
Revision Date: N/A
Expiration Date: January 26, 2028

Product/Series Name: Coulissant Simple PVC 9420

Report Number: SPL22002-10_C_HSOX_1_A1
Operator Type: HSOX
Frame/Sash Type: VY / VY
Specification: CSA A440.2-22
Simulated By: Veridis Solutions
Air Leakage Report No: AI-04422-A1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

Administrator's Signature:

National Accreditation & Management Institute, Inc,
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com

ER Values

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor(M)	SHGC (w)	VT	Air Leakage	ER
1179-003-0001-01	3mm_7/8_PCl-arg95-8071, su	0.082(#3)	1.60	0.55	0.61	0.3	36
1179-003-0002-01	3-3, 7-8, GCl-arg95-8071#3, ss	0.082(#3)	1.61	0.54	0.61	0.3	35
1179-003-0003-01	3-3, 7-8, GCl-arg95-8071#3, ss, Grids<1"	0.082(#3)	1.61	0.49	0.54	0.3	32