NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016946**
DATE:	**04/07/2026**
CERTIFICATION PROGRAM:	**Fire**
COMPANY:	**Carter Lumber**
CODE:	**3091-1**
EXPIRATION DATE:	**04/30/2030**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Carter Lumber Corporation **184 Pleasant Shade Drive** **Emporia, VA 23847**	**Worldwide Door Components** **4-1/2" Wide Composite Frame -** **4ever Frame, J-CP-4F** Manufacture Specific Fire Door Frames for Single Swing Only Installation in 20 Minute Locations **Maximum Frame Size: 38.5" x 81.5"** **Minimum Width: 4-1/2"** **Minimum Thickness: 1-1/2"**

SPECIFICATION	PRODUCT RATING
UL 10(c) (2009) **CAN4 S104(2010)**	**20 Minute-With Hose Stream** **Positive Pressure** **Category C- Proprietary Frame**
TEST REPORT	
Intertek Test Report No: 100719286COQ-003	

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com