NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016963**
DATE:	**04/28/2026**
CERTIFICATION PROGRAM:	**Fire**
COMPANY:	**Builders Hard**
CODE:	**435-1**
EXPIRATION DATE:	**04/30/2030**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Builder's Hardware, Inc. **5615 E. Powhatan Ave.** **Tampa, FL 33610**	**Plastpro's 20 Minute Positive Pressure** **Fire Door Assemblies w/o Hose Stream** Manufacturer Specific Fire Doors for Single or Double Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single or Double Swing Only **Maximum Size: 3'0" x 8'0"** **Minimum Thickness: 1-3/4"**

SPECIFICATION	PRODUCT RATING
NFPA 252 (1999) **UL 10C (2009)** **UBC Standard 7-2 (1997)**	**20 Minute-Positive Pressure** **Without Hose Stream** **Category B Door-Additional Edge Seal Required** (unless specified in individual manufacturer's listing) **For Use in Category C Frame** (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
Intertek Test Report No: 3182549MID-005, 100644112MID-002, 100644112MID-004, 3178456MID-003, 3182549MID-005b, 100359215MID-010b

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com