NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016966
DATE: 05/13/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Guangzhou Xiya
CODE: 2902-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Guangzhou Xiya Bldg. Material Co., Ltd. **Room 729, 7th Floor, Kaisheng Int. Plaza,** **521 Xicha Road,Tongde Street,Baiyun** **District, Guangzhou City, China 510407**	**Series "MT150-76/28"** **Aluminum Lifting Sliding Door** Configuration: OX Glazing: Insulating Glass (Tempered) Frame: W-2438mm(95.98") H-2438mm(95.98") Panel: W-1201mm(47.28") H-2297mm(90.43") DLO: W-1119mm(44.06") H-2165mm(85.24")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	**Class CW-PG40 2438 x 2438 (96 x 96)-SD** **Design Pressure: ±11920 Pa (±40 psf)** **Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)**

Product Tested By: Intertek, PLC
Report No: 250714062GZC-003
Expiration Date: **April 30, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com