NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016978.02
DATE: 05/05/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Dyke Ind.
CODE: 419-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Dyke Industries, Inc. **2349 Silver Star Road** **Orlando, FL 32804**	**Series "Contours (S-2500) Steel Wood Swinging Door"** **Opaque Steel Inswing Side Hinged Door** Configuration: X Frame: W-953mm(37.50") H-2076mm(81.75") Panel: W-908mm(35.75") H-2010mm(79.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **AAMA/WDMA/CSA 101/I.S.2/A440-17** **CSA A440S1-17**	**Class R-PG35 953 x 2076 (38 x 82)-LW SHD** **Design Pressure: 1680 Pa (35 psf)** **Negative Design Pressure: 1920 Pa (40 psf)** **Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)** **Canadian Air Infiltration/Exfiltration Level: A2**

Product Tested By: Molimo, LLC
Report No: 31064.01-201-12
Expiration Date: **May 31, 2030**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com