

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016986
DATE: 05/11/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Anhui Guo Jian
CODE: 3111-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Anhui Guo Jian Door & Window Curtain Wall Engineering Co., Ltd Shouxian County Xinqiao Int. Ind. Park Pioneer Park, Anhui, China	Series "90" Aluminum Dual-Action Window (Thermal Break) Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1257mm(49.49") H-1800mm(70.87") Vent: W-1201mm(47.28") H-1744mm(68.66") DLO: W-1067mm(42.01") H-1610mm(63.39")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	Class LC-PG25 1257 x 1800 (49 x 71)-DAW Design Pressure: ±1200 Pa (±25 psf) Water Penetration Resistance Test Pressure: 180 Pa (3.76 psf)

Product Tested By: Intertek, Inc
Report No: 260128001SHF-001
Expiration Date: **February 28, 2030**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com