NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016987.03
DATE: 05/12/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Robinson
CODE: 3167-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Robinson Windows, LLC **13780 Benchmark Drive** **Farmers Branch, Texas 75234**	**Series "100"** **Vinyl Side Load Single Hung Window** Configuration: O/X Glazing: IG- Ext. 3/32" Annealed Glass/Int. 3/32" Annealed Glass/0.090" Saflex PVB Interlayer/3/32" Annealed Glass Frame: W-1203mm(47.36") H-1816mm(71.50") Sash: W-1156mm(45.51") H-908mm(35.75") DLO: W-1070mm(42.13") H-825mm(32.48")

SPECIFICATION	PRODUCT RATING
ASTM E1886-19 **ASTM E1996-23**	**Design Pressure: ±2400 Pa (±50 psf)** **Missile Level D**

Product Tested By: Construction Consulting Laboratory
Report No: CCL 26-055R
Expiration Date: **February 28, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com