NFRC Product Certification Authorization Report

Manufacturer: XIAMEN KDSBUILDING MATERIAL CO. LTD
Product Series: 140 Vinyl Sliding Door
Simulation Lab: SFTL
Initial Cert. Date: 05/19/2026

Street: 4TH FLOOR.CROSS-STRAIT CENTER,FUXIANG, 159 QIANPU ROAD SIMING DISTRICT XIANEN CHINA
Product Type: DDSG
Sim. Report #: QA-5714e
Re-Certification Date:

City/State/Zip: Xiamen, Fujian Province 361008
Air Leakage:
Sim. Report Date: 02/13/2026
Revised Date: 01/01/1970

Print Date: 05/19/2026
Test Date: 01/11/2026
Expiration Date: 01/11/2031

CPD Number: XKM-M-5 **IA: National Accreditation And Management Institute**

Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00001-00001	6CL-14Arg-6WT172(3)	VR/VY	2	0.034(3)	0.551	A1-D	Fill 1: ARG (90)	N		CL	0.32	0.36	0.51	48
	00002-00001	6CL-14Arg-6SDF178(3)	VR/VY	2	0.052(3)	0.551	A1-D	Fill 1: ARG (90)	N		CL	0.32	0.37	0.55	48
	00003-00001	6CL-14Arg-6SGR168(3)	VR/VY	2	0.051(3)	0.551	A1-D	Fill 1: ARG (90)	N		CL	0.32	0.41	0.49	48

Baseline Information

Test Lab	Test Date	Test Size	Tested U-Value	Standard U-Value	Test Report Number
TFTL	**01/11/2026**	2000mm x 2000mm	0.338	0.328	MED-5714s

Comments: N/A

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA Signature: