NFRC Product Certification Authorization Report

Manufacturer: Zhongshan Dajiang Windows
Street: No.36 Keji West Road, Zhongshan * Guangdong, 528437, China
City/State/Zip: Guang Dong, Zhong Shan 528437

Product Series: 80 Dual Action Window
Product Type: DATT
Air Leakage: ≤ 0.3

Simulation Lab: SFTL
Sim. Report #: MED-6348a
Sim. Report Date: 03/16/2026

Initial Cert. Date: 05/12/2026
Re-Certification Date:
Revised Date: 01/01/1970

Print Date: 05/18/2026

Test Date: 02/15/2026

Expiration Date: 02/15/2031

CPD Number: ZDW-M-2 | **IA: National Accreditation And Management Institute**

Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00001-00001	6|X179(2)-5|XCL-20AR90T3	AT/AT	2	0.048(2)	0.787	TS-D	Fill 1: ARG (90)	N		CL	0.32	0.31	0.52	57
	00002-00001	6|X179(2)-6|YEA(4)-18AR90T3	AT/AT	2	0.048(2), 0.146(4)	0.708	TS-D	Fill 1: ARG (90)	N		CL	0.28	0.29	0.48	47
	00003-00001	6|X179(2)-5|XCL-5|XCL-12AR90T3	AT/AT	3	0.048(2)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.27	0.28	0.47	65
	00004-00001	6|X179(2)-6|X179(4)-5|XCL-12AR90T3	AT/AT	3	0.048(2), 0.048(4)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.22	0.25	0.42	65
	00005-00001	6|X179(2)-6|X179(4)-6|YEA(6)-12AR90T3	AT/AT	3	0.048(2), 0.048(4), 0.146(6)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.21	0.24	0.39	60
	00006-00001	6|X106_6C(2)-6|YEA(4)-18AR90T3	AT/AT	2	0.065(2), 0.146(4)	0.708	TS-D	Fill 1: ARG (90)	N		CL	0.28	0.18	0.28	47
	00007-00001	6|X106_6C(2)-6|X106_6C(4)-6|YEA(6)-12AR90T3	AT/AT	3	0.065(2), 0.065(4), 0.146(6)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.21	0.13	0.13	60
	00008-00001	6|X119_6C(2)-6|YEA(4)-18AR90T3	AT/AT	2	0.041(2), 0.146(4)	0.708	TS-D	Fill 1: ARG (90)	N		CL	0.28	0.16	0.28	47
	00009-00001	6|X119_6C(2)-6|X119_6C(4)-5|XCL-12AR90T3	AT/AT	3	0.041(2), 0.041(4)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.22	0.11	0.14	65
	00010-00001	6|X119_6C(2)-6|X119_6C(4)-6|YEA(6)-12AR90T3	AT/AT	3	0.041(2), 0.041(4), 0.146(6)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.21	0.10	0.13	60

Baseline Information

Test Lab	Test Date	Test Size	Tested U-Value	Standard U-Value	Test Report Number
TFTL	**02/15/2026**	1200mm x 1500mm	0.292	0.287	MED-6468b

Comments: Air Leakage Rpt: MED-6348c.

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA Signature: