NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016864.06
DATE: 06/03/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Milliken
CODE: 994-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Milliken Millwork, Inc. **6361 Sterling Drive North** **Sterling Heights, MI 48312**	**Series "Design Pro/Smooth Pro (F-3500)** **Fiberglass Swinging Door"** **Glazed Fiberglass** **Inswing Side Hinged Door** Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-946mm(37.25") H-2483mm(97.75") Panel: W-908mm(35.75") H-2416mm(95.13") DLO: W-530mm(20.88") H-2003mm(78.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **AAMA/WDMA/CSA 101/I.S.2/A440-17** **CSA A440S1-17**	**Class LC-PG35 946 x 2483 (38 x 98)-LW SHD** **Design Pressure: 1680 Pa (35 psf)** **Negative Design Pressure: 1920 Pa (40 psf)** **Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)** **Canadian Air Infiltration/Exfiltration Level: A3**

Product Tested By: Molimo, LLC
Report No: 31059.01-201-12
Expiration Date: **June 30, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com