NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016917.12
DATE: 06/17/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Steves and Sons
CODE: 1846-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Steves and Sons Corporation **203 Humble Avenue** **San Antonio, TX 78225**	**Series "Xinyu"** **Glazed Outswing Fiberglass** **Side-Hinged Doors** Configuration: XX Glazing; Insulating Glass (Tempered) Frame: W-1880mm(74") H-2070mm(81.50") Panel: W-908mm(35.75") H-2007mm(79") DLO: W-533mm(21") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
ASTM E283-04 **ASTM E330-14** **ASTM E331-00**	**Design Pressure: +35/-35 psf** **Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)**

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01524097
Expiration Date: **May 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com