# NOTICE OF PRODUCT CERTIFICATION

**CERTIFICATION NO:** NI017024
**DATE:** 06/23/2026
**CERTIFICATION PROGRAM:** Structural
**COMPANY:** Guangzhou Top.
**CODE:** 2903-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| **Guangzhou Topbright Bldg. Material Co., Ltd. Room 907, CaiHui Information & Science Bldg. A, No 98 Yuexi North Road Baiyun District, Guangzhou, China 510000** | **Series "TB 80AW.HI"**<br>**Aluminum Dual-Action Window**<br>Configuration: X<br>Glazing: Insulating Glass (Tempered)<br>Frame: W-1250mm(49.21") H-1850mm(72.83")<br>Vent: W-1186mm(46.69") H-1782mm(70.16")<br>DLO: W-1060mm(41.73") H-1660mm(65.35") |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| **AAMA/WDMA/CSA 101/I.S.2/A440-11** | **Class CW-PG70 1250 x 1850 (49 x 73)-DAW**<br>**Design Pressure: ±3360 Pa (±70 psf)**<br>**Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf)** |

Product Tested By: Intertek, PLC
Report No: 220714041GZC-001
Expiration Date: **June 30, 2030**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.**
**4794 George Washington Memorial Highway**
**Hayes, VA 23072**
**Tel: (804) 684-5124**
**Email: nami@namiinc.com**