NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI017027.01
DATE: 06/24/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Plyco
CODE: 765-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Plyco Corporation **dba Modern Door Corporation** **500 Industrial Road/PO Box 386** **Elkhart Lake, WI 53020**	**Series "CTB500 "** **Aluminum Horizontal Sliding Window** **(w/"Step Saver" Trim)** Configuration: OX Glazing: Insulating Glass (Annealed) Frame: W-1511mm(59.50") H-1207mm(47.50") Sash: W-759mm(29.88") H-1156mm(45.50") DLO: W-692mm(27.25") H-1105mm(43.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **AAMA/WDMA/CSA 101/I.S.2/A440-17**	**Class LC-PG30 1511 x 1207* (60 x 48*)-HS** **Design Pressure: 1440 Pa (30 psf)** **Positive Design Pressure: 2160 Pa (45 psf)** **Negative Design Pressure: 2160 Pa (45 psf)** **Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)**

Product Tested By: Molimo, LLC
Report No: 32436.01-301-11
Expiration Date: **February 28, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION & MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com