NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI017029.03
DATE: 06/24/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Plyco
CODE: 765-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Plyco Corporation **dba Modern Door Corporation** **500 Industrial Road/PO Box 386** **Elkhart Lake, WI 53020**	**Series "Plyco VAE 190"** **Vinyl Horizontal Sliding Window** **(w/Step Saver Trim & w/Sill Riser)** Configuration: OX Glazing: Insulating Glass (Annealed) Frame: W-1816mm(71.50") H-1410mm(55.50") Sash: W-889mm(35") H-1346mm(53") DLO: W-803mm(31.63") H-1260mm(49.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	**Class LC-PG40 1816 x 1410 (72 x 56)-HS** **Design Pressure: ±1920 Pa (±40 psf)** **Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)**

Product Tested By: Intertek, PLC
Report No: Q0352.01-201-44
Expiration Date: **June 30, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION & MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com