NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI017032
DATE: 06/26/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Ameritech Mill
CODE: 474-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ameritech Millworks, LP. **2300 West Marshall Drive** **Grand Prairie, TX 75051**	**"Contours" Premium Steel Door w/Steel Edge Opaque In-Swing Door w/Dunbarton Redi-Flex 90. Min Steel Frame & Standard AFCO Threshold** Configuration: X Frame: W-990mm(38.94") H-2201mm(86.63") Panel: W-909mm(35.75") H-2005mm(83.25")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	**Design Pressure: 3161 Pa (66 psf)** **Negative Design Pressure: 3161 Pa (66 psf)** **Water Penetration Resistance Test Pressure: 0 Pa (0 psf)** **Large Missile Impact Rated** **Qualifies Configurations: X**

Product Tested By: National Certified Testing Laboratories/Certified Testing Laboratories, Inc.
Report No: NCTL-210-3844-1/NCTL-210-3844-1A/CTLA1167W-1/CTLA-1167W-2A/W-1546/W-1788/W-1819/W-1897/W-1905
Expiration Date: **June 30, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com