Notice of Product Certification

Company: Portes Metalliques Jacob Inc.

Address: 1321 Marie-Victorin, St-Bruno, QC, Canada J3V 6B7
Code: 1146-1
Certification No: 1146-023
Certification Date: July 16, 2026
Revision Date: N/A
Expiration Date: November 11, 2027

Product/Series Name: Grand fixe PVC

Report Number: SPL21004-11_C_LFIXD-P_A1
Operator Type: FIXD
Frame/Sash Type: VY/ NA
Specification: CSA A440.2-22
Simulated By: Veridis Solutions
Air Leakage Report No: AI-03741-B1 Rev.3
Revision Notes: N/A

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada

National Accreditation & Management Institute, Inc,
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com

Administrator's Signature: _____

ER Values

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (M)	SHGC (w)	VT	Air Leakage	ER
1146-023-0001-01	9702XIB_3mm_1 1_4_8071#2-arg90-PCl-arg90-8071#5, sw	0.082(#2) 0.082(#5)	1.02	0.46	0.56	0.0	44
1146-023-0002-01	GL_3mm_1 1_4_8071#2-arg90-PCl-arg90-8071#5, sw	0.082(#2) 0.082(#5)	0.97	0.46	0.56	0.0	45
1146-023-0003-01	BF_3mm_1 1_4_8071#2-arg90-PCl-arg90-8071#5, sw	0.082(#2) 0.082(#5)	0.97	0.46	0.56	0.0	45
1146-023-0004-01	3-3, 7-8, PCl-arg97-PTLX#3, ss	0.082(#3)	1.52	0.58	0.62	0.0	40
1146-023-0005-01	3-3, 7-8, PCl-arg97-PTLX#3, ms	0.082(#3)	1.55	0.58	0.62	0.0	40
1146-023-0006-01	3-3, 7-8, PCl-arg97-PTLX#3, ms, Grids<1"	0.082(#3)	1.55	0.52	0.55	0.0	36
1146-023-0007-01	3-3, 7-8, PCl-arg97-PTLX#3, ms, Grids>=1"	0.082(#3)	1.55	0.46	0.49	0.0	33
1146-023-0008-01	4-4, 7-8, PCl-arg97-PTLX#3, ss	0.081(#3)	1.51	0.57	0.61	0.0	40
1146-023-0009-01	4-4, 7-8, PCl-arg97-PTLX#3, ms	0.081(#3)	1.54	0.57	0.61	0.0	39
1146-023-0010-01	4-4, 7-8, PCl-arg97-PTLX#3, ms, Grids<1"	0.081(#3)	1.54	0.51	0.54	0.0	36
1146-023-0011-01	4-4, 7-8, PCl-arg97-PTLX#3, ms, Grids>=1"	0.081(#3)	1.62	0.45	0.48	0.0	31
1146-023-0012-01	4-6, 7-8, PCl-arg97-PTLX#3, ss	0.081(#3)	1.48	0.56	0.60	0.0	40
1146-023-0013-01	4-6, 7-8, PCl-arg97-PTLX#3, ms	0.081(#3)	1.52	0.56	0.60	0.0	39
1146-023-0014-01	4-6, 7-8, PCl-arg97-PTLX#3, ms, Grids<1"	0.081(#3)	1.63	0.51	0.54	0.0	34
1146-023-0015-01	4-6, 7-8, PCl-arg97-PTLX#3, ms, Grids>=1"	0.081(#3)	1.67	0.45	0.48	0.0	29
1146-023-0016-01	3-3-3, 1 1-4, PCl-arg97-PCl-arg97-PTLX, ms	0.082(#5)	1.19	0.52	0.57	0.0	44
1146-023-0017-01	3-3-3, 1 1-4, PCl-arg97-PCl-arg97-PTLX, ms, Grids<1"	0.082(#5)	1.20	0.47	0.50	0.0	41
1146-023-0018-01	3-3-3, 1 1-4, PCl-arg97-PCl-arg97-PTLX, ms, Grids>=1"	0.082(#5)	1.20	0.42	0.45	0.0	38
1146-023-0019-01	3-3-3, 1 1-4, PTLX-arg97-PCl-arg97-PTLX, ms	0.082(#2) 0.082(#5)	0.97	0.47	0.54	0.0	46
1146-023-0020-01	3-3-3, 1 1-4, PTLX-arg97-PCl-arg97-PTLX, ms, Grids<1"	0.082(#2) 0.082(#5)	1.00	0.42	0.48	0.0	42
1146-023-0021-01	3-3-3, 1 1-4, PTLX-arg97-PCl-arg97-PTLX, ms, Grids>=1"	0.082(#2) 0.082(#5)	1.01	0.37	0.43	0.0	39
1146-023-0022-01	5-5, 7-8, PCl-arg97-PTLX#3, ss	0.082(#3)	1.48	0.53	0.60	0.0	38
1146-023-0023-01	5-5, 7-8, PCl-arg97-PTLX#3, ms	0.082(#3)	1.52	0.53	0.60	0.0	37
1146-023-0024-01	5-5, 7-8, PCl-arg97-PTLX#3, ms, Grids<1"	0.082(#3)	1.64	0.47	0.53	0.0	31
1146-023-0025-01	5-5, 7-8, PCl-arg97-PTLX#3, ms, Grids>=1"	0.082(#3)	1.72	0.42	0.47	0.0	27
1146-023-0026-01	6-6, 7-8, PCl-arg97-PTLX#3, ss	0.081(#3)	1.49	0.51	0.59	0.0	37

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (M)	SHGC (w)	VT	Air Leakage	ER
1146-023-0027-01	6-6, 7-8, PCl-arg97-PTLX#3, ms	0.081(#3)	1.53	0.51	0.59	0.0	36
1146-023-0028-01	6-6, 7-8, PCl-arg97-PTLX#3, ms, Grids<1"	0.081(#3)	1.67	0.46	0.52	0.0	30
1146-023-0029-01	6-6, 7-8, PCl-arg97-PTLX#3, ms, Grids>=1"	0.081(#3)	1.53	0.41	0.46	0.0	30
1146-023-0030-01	4-4-4, 1 1-4, PCl-arg97-PCl-arg97-PTLX, ms	0.081(#5)	1.21	0.51	0.56	0.0	43
1146-023-0031-01	4-4-4, 1 1-4, PCl-arg97-PCl-arg97-PTLX, ms, Grids<1"	0.081(#5)	1.22	0.46	0.50	0.0	40
1146-023-0032-01	4-4-4, 1 1-4, PCl-arg97-PCl-arg97-PTLX, ms, Grids>=1"	0.081(#5)	1.23	0.41	0.44	0.0	37
1146-023-0033-01	4-4-4, 1 1-4, PTLX-arg97-PCl-arg97-PTLX, ms	0.081(#2) 0.081(#5)	1.00	0.45	0.53	0.0	44
1146-023-0034-01	4-4-4, 1 1-4, PTLX-arg97-PCl-arg97-PTLX, ms, Grids<1"	0.081(#2) 0.081(#5)	1.03	0.41	0.48	0.0	41
1146-023-0035-01	4-4-4, 1 1-4, PTLX-arg97-PCl-arg97-PTLX, ms, Grids>=1"	0.081(#2) 0.081(#5)	1.05	0.36	0.42	0.0	38